



6465 North Quail Hollow Road | Suite 401
Memphis, Tennessee 38120
901.646.5075

720 North Lamar Blvd | Suite A
Oxford, Mississippi 38655
662.550.4454

dt-designstudio.com
info@dt-designstudio.com

Addendum No. 2
Senatobia Sports Park Maintenance Building
Date: 5/23/17

Please note the following clarifications to the Contract Documents:

1. On A 4.01 it shows a prefinished downspout connector but doesn't give any info as to what type.
Eliminate the prefinished downspout connector and just include a cost for a 12"x36" precast concrete splashblock at each downspout instead.
2. Will the 20 year weather tightness warranty be required on the exposed fastener roof?
No, the 20-year weather tightness warranty will not be required. However, the finish warranty from the manufacturer and the 1 year warranty from the contractor on all improvements associated with this project shall apply.

End of Addendum No. 2