



ETC Engineers & Architects, Inc.

ENGINEERS ■ ARCHITECTS ■ PLANNERS

■ 1510 SOUTH BROADWAY, LITTLE ROCK, AR 72202 ■ PHONE 501-375-1786 ■ FAX 501-375-1277 ■

ADDENDUM NO.4

DATE: December 13, 2016
PROJECT: Emergency Dispatch Center
Paragould, AR
ETC Project No.: 150303CPAG

TO ALL PROSPECTIVE BIDDERS:

This Addendum forms a part of the Contract Documents and modifies or interprets the Project Manual and drawings as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

PROJECT MANUAL:

ITEM 1:

Refer to Section 28 3100 Fire Detection and Alarm, Part 1 General, 1.5 Warranty, Paragraph C. Delete Paragraph C. There will be no maintenance contract with the Owner.

ITEM 2:

Refer to Section 28 3100 Fire Detection and Alarm. The alarm system will not be monitored by an external monitoring company. Delete any reference to such.

ELECTRICAL:

The City Utility Company requires the following for this Project: The power feed from the transformer to the main disconnect at the building shall be a parallel feed of 350 mcm copper circular mill wire inside the conduit. Please include this in the electrical price.

DRAWINGS:

ITEM 1:

Refer to Sheet C-103, Note 8. The sprinkler system is deleted. There will be no sprinkler system in the Project.

ITEM 2:

Refer to Sheet C-103, Note 7. Clarification: All areas of the property within the property lines that do not receive hard surface parking surface or side walks shall receive solid sod.

BUILDING A BETTER WORLD

■ e-mail: etc@etcengineersinc.com ■





ETC Engineers & Architects, Inc.

ENGINEERS ■ ARCHITECTS ■ PLANNERS

■ 1510 SOUTH BROADWAY, LITTLE ROCK, AR 72202 ■ PHONE 501-375-1786 ■ FAX 501-375-1277 ■

ITEM 3:

Refer to Sheet A-101. Tornado Resistant Mechanical Enclosure. Allow \$ 2,000.00 for the fabrication and installation of the steel gate into the enclosure. Design to follow from the Architect.

ITEM 4:

See attached Sheet A-120, Toilet Plans & Elevations, dated December 13, 2016. This is a new sheet and is hereby made a part of this Project.

End of Addendum 4

BUILDING A BETTER WORLD

■ e-mail: etc@etcengineersinc.com ■

