



1. VOLUME OF CONC. FOR VERTICAL OVERBENDS SHALL BE SIZED FOR THE MAXIMUM DESIGN PRESSURE +100 P.S.I. SURGE BY THE RESIDENT ENGINEER.
2. NO SPECIAL PAYMENT FOR REINF. RODS REQ'D IN OVERBENDS.
3. SIZE OF TEE REFERS TO BRANCH SIZE



SCALE: NONI

NOTE: BLOCKING DETAILS APPLY TO WATER MAINS AND SEWER FORCE MAINS




SCALE: NONI


### TYPICAL MANHOLE ELEVATION

### TYPICAL DROP MANHOLE ELEVATION

SCALE: NONE



NOTE: VALVES AND HYDRANTS SHALL BE FURNISHED TO MEET THE SPECIFICATIONS OF PEOPLE'S WATER COMPANY.



SCALE: NONE

WHERE SUBGRADE IS SOFT,  
PROVIDE SELECT GRANULAR  
BEDDING AS DIRECTED

TRENCH JACKS MAY BE USED IN LIEU OF, OR IN COMBINATION WITH, CROSS BRACES SHORING IS NOT REQUIRED IN SOLID ROCK, HARD SHALE, OR HARD SLAG. WHERE DESIRABLE, STEEL SHEET PILING AND BRACING OF EQUAL STRENGTH MAY BE SUBSTITUTED FOR WOOD.

MOVABLE TRENCH BOX MAY BE USED IN LIEU OF TRENCH SHORING.



### ANGLE OF REPOSE DIAGRAM

1111 N. 19th ST. MONROE, LA. 71201 PH. 318-325-1791

## PROJECT: A NEW HOUSING DEVELOPMENT

# BRIARWOOD ESTATES

A KWL PROPERTIES, LLC DEVELOPMENT

XXXX SOUTH WASHINGTON STREET  
DASTON, LA 71004

DRAWING REVISIONS	
DATE	DESCRIPTION
10/12/17	RE-ISSUE FOR PRICING
12/14/17	RE-ISSUE FOR PRICING
4/23/18	RE-ISSUE FOR CITY COMMENTS
6/05/18	ISSUED FOR CONSTRUCTION

Drawn By: DAH

Checked By: DRA

SHEET

## C2.01

Date: 10.16.17

Project No.: 16-0025

File No.:

DESCRIPTION:

DETAILS  
SHEET 1 OF 4