



## **ADDENDUM NO.2**

PROJECT: Forrest City New City Hall, Forrest City, AR  
ETC Project No.: 163902CFC  
Date: December 02, 2016

This Addendum becomes a part of the CONTRACT DOCUMENTS, modifies and supplements them as follows:

In order to correct a discrepancy between the Project Manual Sections 08400 and 08410 and the Drawings, (Sheets A2.1, A3.1, and A5.3) -Revise the Project Drawings in the following manner:

Sheet A2.1 and Sheet A3.1-Revise Note 8.4 to correctly indicate a Kawneer 451T System rather than 451UT

Revise Note 8.9 to correctly indicate Kawneer 350 Med. Stile in lieu of 360 Insulclad Exterior Aluminum Swinging Doors

Sheet A5.3 – Revise all notes to correctly indicate the 451T System and 350 Med. Stile Doors

In order to correct a discrepancy between the Project Manual Section 09300 and Sheet 6.2:

Revise Note 5 on Sheet 6.2 to indicate 4x4 Wall Tile as Specified in lieu of 2x2 Mosaic