

**MSA**

**MATT SILAS ARCHITECT**

212 East Washington Avenue

P.O. Box 1702

Jonesboro, Arkansas 72403

tel: (870) 268-0500

fax: (870) 268-0501

email: [mattsilas@sbcglobal.net](mailto:mattsilas@sbcglobal.net)

website: [mattsilasarchitect.com](http://mattsilasarchitect.com)

**ADDENDUM NUMBER 2**

**ISSUE DATE: SEPTEMBER 24, 2017**

**PROJECT:**

**ST. PAUL CATHOLIC CHURCH PARISH LIFE CENTER  
POCAHONTAS, ARKANSAS**

**OWNER:**

**ST. PAUL CATHOLIC CHURCH**

**TO: PROSPECTIVE BIDDERS**

Please review items noted in this addendum. This addendum forms a part of the contract documents and modifies the bidding documents as indicated below.

**GENERAL**

1. Water Main Extension: Refer to Sheet C-1.3 - The Owner shall be responsible for the 8" CL200 PVC water main extension, the 6" CL50 fire line including the fire hydrant and all other water system items 2 feet west of the western sidewalk. The contractor shall be responsible for those items east of such point.
2. Patcraft commercial carpet shall be listed as an acceptable carpet manufacturer.

**ELECTRICAL**

1. Refer to Sheet E-0.1, Lighting Fixture Schedule:
  - a. The exterior emergency light fixture (12<sup>th</sup> mark on the schedule) shall be changed to SELWT29-NC-BZ-SD.
  - b. The interior 2-head emergency light fixture shown on the electrical plans and not listed on the schedule is Sure-Lite SEL25SD manufactured by Eaton / Cooper Industries.
2. Refer to Sheet E-1.0 – Site Electrical Plan:
  - a. Telephone / Data Utility Service Note shall read as follows: "At a minimum provide (1) 4" conduit to service location at street for telephone / internet service and (1) 4" conduit for future interconnection to utility pole west and near the north end (rear) of existing rectory carport. Turn conduit for future interconnection up pole 4 feet and cap." Coordinate trenching such that root systems of existing trees are not disturbed.

**END OF ADDENDUM NO. 2**