

ADDENDUM NO. 4

First Community Branch Bank
Brookland, AR

Roark · Perkins · Perry · Yelvington
Architects
713 W. 2nd Street
Little Rock, AR 72201
501-372-0272

Project #1654

March 4, 2020

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated January 9, 2019 as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This addendum consists of 1 page.

I. CHANGES TO DRAWINGS

- A. Omit all references to Zip Board or Zip System. Exterior wall to have sheathing, rigid insulation, and weather barrier. Refer to Section 06 16 43 for gyp. sheathing, and provide plywood or OSB sheathing where required by structural. Weather barrier to be Tyvek, Commercial Wrap, or approved equal with special 10 year warranty.

END OF ADDENDUM