



ADDENDUM NO. 1

Date: November 6, 2020
Project Name: Jet-A Fuel System Installation
Owner: Delta Regional Airport Authority
Garver Project No. 19A10120

This addendum shall be a part of the Plans, Contract Documents and Specifications to the same extent as though it were originally included therein, and it shall supersede anything contained in the Plans, Contract Documents, and Specifications with which it might conflict. This addendum, including all attachments, shall become part of the Contract and all provisions of the Contract shall apply thereto. The time provided for completion of the Contract has not been changed as noted in this addendum. Acknowledgement of receipt of this addendum must be noted in the appropriate section of the Proposal and included with the Contract Documents.

A. QUESTIONS AND ANSWERS

1. **Question:** What is the Engineer's estimate for this project?

Answer: The Engineer's estimate ranges from \$210,000 to \$250,000.

B. SPECIFICATIONS

1. Revise Section 010200 – Instructions to Bidders as follows:
 - a. Revise the second paragraph under 1. Preparation of Bid by adding the following sentence to the end of the paragraph:
“The Owner will award either Schedule 1 or Schedule 2, depending on the available funding.”
2. Revise Section SS-131 Jet-A Fueling Facility as follows:
 - a. Add Item 13 under SS-131-1.1.F. Jet-A Fuel System Installation (Schedule 1) as follows:
“Contractor shall provide a wheeled fire extinguisher with a rating of at least 80-B:C and a minimum agent capacity of 125 pounds.”
 - b. Add Item 13 under SS-131-1.1.G. Jet-A Fuel System Installation (Schedule 2) as follows:
“Contractor shall provide a wheeled fire extinguisher with a rating of at least 80-B:C and a minimum agent capacity of 125 pounds.”
 - c. Add Item 3 under SS-131-1.1.I. Emergency Fuel Shut-Off System as follows:
“Contractor shall replace the existing fire extinguisher with a wheeled fire extinguisher with a rating of at least 80-B:C and a minimum agent capacity of 125 pounds.”

By: *Jordan Culver*

Jordan Culver, P.E.
Project Manager

Attachments:

No Attachments

END OF ADDENDUM NO. 1



Digitally Signed: November 6, 2020