


ADDENDUM NO. 2

Date: December 1, 2020
Project Name: Jet-A Fuel System Installation
Owner: Delta Regional Airport Authority
Garver Project No. 19A10120

This addendum shall be a part of the Plans, Contract Documents and Specifications to the same extent as though it were originally included therein, and it shall supersede anything contained in the Plans, Contract Documents, and Specifications with which it might conflict. This addendum, including all attachments, shall become part of the Contract and all provisions of the Contract shall apply thereto. The time provided for completion of the Contract has not been changed as noted in this addendum. Acknowledgement of receipt of this addendum must be noted in the appropriate section of the Bid Form and included with the Contract Documents.

A. SPECIFICATIONS

1. Revise Section 010200 – Instructions to Bidders as follows:
 - a. Revise the second paragraph of 1. Preparation of Bid by replacing “...*Bidders must submit proposals on both schedules...*” with “...*Bidders may submit a bid for both schedules, or they can submit a bid for just one of the schedules...*”
2. Revise Section Item SS-131 Jet-A Fueling Facility as follows:
 - a. Revise paragraph 1.1.F.10 by adding the following sentence:
 - *The refueling truck refilling equipment shall include an automatic shutdown system that stops the tank loading operation when the fuel servicing vehicle tank is full, in accordance with NFPA 407.*
 - b. Revise paragraph 1.1.G.10 by adding the following sentence:
 - *The refueling truck refilling equipment shall include an automatic shutdown system that stops the tank loading operation when the fuel servicing vehicle tank is full, in accordance with NFPA 407.*

By: 
Jordan Culver, P.E.
Project Manager

Attachments:
A. No Attachments

END OF ADDENDUM NO. 2



Digitally Signed: December 1, 2020