



Andrew Hicks: Project Manager
Phone: (479) 332-5050
andrew@andrewhicksarchitect.com

Re: A BID FOR TWO NEW PROJECT BUILDINGS:

**A. A NEW CAFETERIA AND OFFICE ADDITION-LYNN CAMPUS
PROJECT 1920-3809-002**

**B. A NEW CAFETERIA/MULTI-PURPOSE ROOM BUILDING-STRAWBERRY CAMPUS
PROJECT 1920-3809-001**

Owner: HILLCREST SCHOOL DISTRICT

South Main /Highway 25,
PO Box 50
Strawberry, Arkansas 72469
Superintendent of Schools, Mr. Greg Crabtree

Projects to be located on:

Lynn School Campus- Lynn, Arkansas

Strawberry School Campus- Strawberry, Arkansas

ADDENDUM #3

March 16, 2021

**Modifications or clarifications to original plans and specifications FOR
BOTH PROJECTS UNLESS NOTED OTHERWISE:**

1. The metal building manufacturers have been looking for clarification on this –
In the Previous design of these projects, the structural engineer required

**A NEW CAFETERIA and OFFICE ADDITION-LYNN CAMPUS
A NEW CAFETERIA/MULTI-PURPOSE ROOM-STRAWBERRY CAMPUS**

Hillcrest School District
Addendum #3 Page 1 of 2

Intermediate Moment Framing In lieu of Ordinary Moment Framing. It's noticed this time that the Strawberry Campus has removed that requirement, but Lynn Campus still has it. Can you have someone verify with ECI if this requirement is valid on the Lynn Campus?

THE RESPONSE from ECI:

The seismic design category for Lynn is D, therefore "INTERMEDIATE MOMENTFRAMES" are required.

The seismic design category for Strawberry is C, therefore "ORDINARY MOMENT FRAMES" are permitted.

2. Friday March 19th at 12:00 pm (noon). Will be the cut-off time for questions on this project.

(End of addendum)

A NEW CAFETERIA and OFFICE ADDITION-LYNN CAMPUS
A NEW CAFETERIA/MULTI-PURPOSE ROOM-STRAWBERRY CAMPUS