

andrew hicks | architect

AHA

PO Box 1525 office 479-332-5050
Fayetteville Arkansas, 72702 cell 501-680-0789
www.andrewhicksarchitect.com

Andrew Hicks: Project Manager
Phone: (479) 332-5050
andrew@andrewhicksarchitect.com

Re: A BID FOR TWO NEW PROJECT BUILDINGS:

**A. A NEW CAFETERIA AND OFFICE ADDITION-LYNN CAMPUS
PROJECT 1920-3809-002**

**B. A NEW CAFETERIA/MULTI-PURPOSE ROOM BUILDING-STRAWBERRY CAMPUS
PROJECT 1920-3809-001**

Owner: HILLCREST SCHOOL DISTRICT

South Main /Highway 25,
PO Box 50
Strawberry, Arkansas 72469
Superintendent of Schools, Mr. Greg Crabtree

Projects to be located on:

Lynn School Campus- Lynn, Arkansas
Strawberry School Campus- Strawberry, Arkansas

ADDENDUM #4
March 18, 2021

**Modifications or clarifications to original plans and specifications FOR
BOTH PROJECTS UNLESS NOTED OTHERWISE:**

1. Refer to addendum #3 item 1 -----The metal building manufacturers have been looking for clarification on this –In the Previous design of these

**A NEW CAFETERIA and OFFICE ADDITION-LYNN CAMPUS
A NEW CAFETERIA/MULTI-PURPOSE ROOM-STRAWBERRY CAMPUS**

Hillcrest School District
Addendum #4 Page 1 of 2

projects, the structural engineer required Intermediate Moment Framing In lieu of Ordinary Moment Framing. It's noticed this time that the Strawberry Campus has removed that requirement, but Lynn Campus still has it. Can you have someone verify with ECI if this requirement is valid on the Lynn Campus?

A revised response has been issued from ECI based on a code exception. The REVISED response from ECI:

The seismic design category for Lynn is C, therefore "ORDINARY MOMENT FRAMES" are permitted.

The seismic design category for Strawberry is C, therefore "ORDINARY MOMENT FRAMES" are permitted.

2. Friday March 19th at 12:00 pm (noon). Will be the cut-off time for questions on this project.

(End of addendum)

A NEW CAFETERIA and OFFICE ADDITION-LYNN CAMPUS
A NEW CAFETERIA/MULTI-PURPOSE ROOM-STRAWBERRY CAMPUS