



FRAMING PLAN
SCALE 1/8"=1'

WALL FRAMING SCHEDULE

EXTERIOR
2x4 SPF No.2 @ 16" O.C. U.N.O.
FULLY SHEATHED w/ BLOCKING
@ 1/3 POINTS

INTERIOR LOAD BEARING
2x4 SPF No.2. SEE PLAN FOR SPACING
@ 16" O.C. IF NOT NOTED, w/ BLOCKING
@ 1/3 POINTS

ROOF DECKING SCHEDULE

DECKING
5/8" O.S.B. RATED DECKING
EDGE NAILS = 10d (3"x0.148") @ 4" O.C.
FIELD NAILS = 10d (3"x0.148") @ 12" O.C.
PROVIDE BLOCKING @ ALL PANEL EDGES

RAFTER TIES

(2)-SIMPSON STRONG TIE H2.5A
OR (2) USP CONNECTORS RT7A
@ EACH RAFTER TRUSS

FLOOR TRUSS DESIGN LOADING

Top Chord Live Load = 50 psf
Top Chord Dead Load = 15 psf
Bottom Chord Live Load = 0 psf
Bottom Chord Dead Load = 10 psf

ROOF TRUSS DESIGN GRAVITY LOADING

Top Chord Live Load = 20 psf
Top Chord Dead Load = 15 psf
Bottom Chord Live Load = 10 psf
Bottom Chord Dead Load = 10 psf

FRAMING PLAN

NEW FACILITY FOR:
TIGER COMMISSARY
JONESBORO, AR

COMM. NO.:
DATE: 12/06/2021
FILE:
PLOT:

