

66 Monroe Avenue, Suite 105, Memphis, TN 38103 Phone (901) 527-9085, Fax (901) 527-9087

Date:November 7, 2023Subject:Trumann Fire Station
801 West Main St., Trumann, Arkansas 72472

Addendum # 3

The following shall be incorporated into the construction documents:

A. All gypsum board walls and ceilings shall have a Level 4 finish, as specified in the Project Manual Section 09250.3.03.B.3. Level 5 finish will not be required for any condition.

END OF ADDENDUM # 3