

**ADDENDUM NUMBER TWO**  
**November 1, 2024**

**Brookland Sportsplex Phase 2**  
**Brookland, Arkansas**

The following additions, deletions and/or revisions shall be made part of the Plans dated October 7, 2024 of the referenced project. This addendum shall have precedence over the plans and specifications on all items listed and described herein, however, it shall not change the intent and requirements of the plans and specifications for any item not specifically mentioned.

**ITEM NO. 1**

**RESPONSES TO QUESTIONS RECEIVED:**

1. Question: Do you have any additional information regarding the type of sealer or desired finish for this?  
**Answer: The question refers to the concession building interior floor finish. The concession building interior concrete shall be sealed concrete with trowelled finish, Rust-oleum's Seal-Krete ([www.seal-crete.com](http://www.seal-crete.com)), SS-10 Silane-Siloxane Waterproofing at all interior rooms or approved equal.**
2. Question: Do you have any specific Vendor/Supplier to use for Sports Light/Pole Light ??  
**Answer: Musco brand is the preferred manufacturer for the sports lighting system, but alternate manufacturers will be considered, in conformance with the specifications. See sheet E201, Section 2 for system requirements.**

**END OF ADDENDUM NO. 2**

