

ADDENDUM NO.1
TO
PLANS AND SPECIFICATIONS
FOR
INDEPENDENCE COUNTY BUILDING RENOVATION FOR USDA
INDEPENDENCE COUNTY, ARKANSAS
M-N 24-025
January 30, 2025

The following revisions shall be made to the plans and specifications and become a part thereof:

1. In the Bid Schedule on Page 18 under Division 26.2 - Lighting the line item "Relocate Exit Sign" is incorrect. We herewith direct you to mark through the words "~~Relocate~~" and "~~2~~" and "~~Ex~~". Please write in "LS" beside "~~Ex~~". New exit signs are to be provided at all exits. Note that code requires a lighted sign above the door and one near floor on the latch side of the door.
2. The canopy at the rear of the building and the wood frame building at the rear of the site are to be moved by the County before construction begins.
3. The new parking area and tree removal will be performed/constructed by the County.

(End of Addendum)

MILLER-NEWELL ENGINEERS, INC.
P.O. Box 705
510 Third Street
Newport, AR 72112

