

ADDENDUM NO. 1
TO
PLANS AND SPECIFICATIONS
FOR
100'x100' STORAGE HANGAR
FRANK FEDERER MEMORIAL AIRPORT
BRINKLEY, ARKANSAS
M-N 24-004

January 29, 2025

The following revision shall be made to the plans and specifications and become a part thereof:

1. On Sheet 7 of the plans the 133'-4" is an error. The dimension is 100'-0".
2. The attached two letters from the Arkansas Health Department are being provided to comply with Health Department guidelines.

(End of Addendum)

MILLER-NEWELL ENGINEERS, INC.
P.O. Box 705
501 Third Street
Newport, AR 72112



Arkansas Department of Health

4815 West Markham Street • Little Rock, Arkansas 72205-3867 • Telephone (501) 661-2000

Governor Sarah Huckabee Sanders

Renee Mallory, RN, BSN, Secretary of Health

Jennifer Dillaha, MD, Director

January 24, 2025

Robert Chatman
MILLER NEWELL ENGINEERS INC
510 THIRD STREET
NEWPORT, AR 72112
(870) 523-6531
milnewengr@aol.com

RE: Project # 136426 PD# 25-0053
Construction of Storage Hangar at Frank Federer Memorial Airport
233 West Cedar
Brinkley, AR

The plans and specifications for the above referenced project have been reviewed and approved by the Plumbing and Natural Gas Section of the Arkansas Department of Health. No deviations from the accepted plans, specifications, and/or addenda will be permitted during construction except by prior written acceptance. This approval is valid for one (1) year from the date on this letter or this acceptance must be re-validated by contacting this office referring to the above referenced file numbers. **Note:** Plans & specifications will be discarded after completion of the review and in no case be retained for more than a six (6) month period.

This approval letter is for the **plumbing portion of this project only**. The architect, engineer, designer, or agent of the owner shall provide all contractors a copy of this letter. Swimming pools, public water/sewer extensions, fire protection systems, sewage disposal systems, and water wells are regulated by other sections of the Arkansas Department of Health, and are subject to plan review approval before construction begins. For more information for food service requirements, please contact Environmental Health Protection at (501) 661-2171.

All plumbing and gas work shall meet minimum state plumbing code standards and be performed by a duly licensed master plumber. While every effort is made to ensure these plans and specifications meet the plumbing & gas codes, the final approval for this project rests with the onsite inspection of the plumbing & gas systems by the certified plumbing inspector. Please refer to any attached comments with this letter regarding required changes or the need for additional plumbing.

For more information regarding this approval, please contact us at (501) 661-2642.

Sincerely,

Josh Hazlewood, Plan Review Examiner
Plumbing & Natural Gas Section
Protective Health Codes

CC: State Plumbing Inspector
Municipal Plumbing Inspector

Project Comments and / or Needed Corrections

Project ID: 136426

PD #25-0053

Project Name: Construction of Storage Hangar and Hangar Access at Frank Federer Airport.

1. **ASPC 712.3 Sump design.** The sump pump, pit and discharge piping shall conform to the requirements of Sections 712.3.1 through 712.3.5.
2. **ASPC 1003.9 Venting of interceptors and separators.** Interceptor sand separators shall be designed so as not to become air bound. Interceptors and separators shall be vented in accordance with one of the methods in Chapter 9.
3. **ASPC 1003.3.7** Gravity grease interceptors shall be designed and tested in accordance with IAPMO/ANSI Z1001. Gravity grease interceptors with fats, oils, and greases disposal systems shall be designed and tested in accordance with ASME A112.14.6 and IAPMO/ANSI Z1001.



Arkansas Department of Health

4815 West Markham Street • Little Rock, Arkansas 72205-3867 • Telephone (501) 661-2000

Governor Sarah Huckabee Sanders

Renee Mallory, RN, BSN, Secretary of Health

Jennifer Dillaha, MD, Director

Engineering Section, Slot 37

Ph (501) 661-2623 Fax (501) 661-2032

www.healthy.arkansas.gov/eng

After Hours Emergency (501) 661-2136

January 24, 2025

Robert W. Chatman, P.E.
Miller-Newell Engineers, Inc.
P.O. Box 705
Newport, AR 72112

RE: FORCE MAIN INSTALLATION
Brinkley Aircraft Storage Hangar
Brinkley Waterworks – Monroe County
Project 136424

Dear Mr. Chatman,

The plans for the above referenced project received by this office on January 16, 2025, have been reviewed and are hereby approved with the following conditions:

1. The Engineering Section relied upon the statements and representations made in the engineer's report, plans and specifications. In case any statement or representation in the aforementioned documents is found to be incorrect, this Approval may be revoked.
2. There shall be no deviation from the plans and specifications unless revised plans and specifications have been first submitted for review and written consent given.
3. The review and approval of the plans and specifications were for functional and sanitary features and in no way constitute an analysis of the structural design nor does it cover any building plumbing.
4. If construction on this project is not started within one year of the date affixed hereto, this Letter of Approval is void.
5. Construction inspection for this project shall be the responsibility of Miller-Newell Engineers, Inc.

One copy of the plans is being retained for our files. When submitting correspondence for this project, be sure and reference our ADH project number 129292.

Sincerely:

Glenn A. Greenway, P.E.
Engineer Supervisor
Engineering Section

GAG: bvt

cc: Brinkley Waterworks — PWS 384